

Water Test Results

Strait Regional Centre for Education - UPDATE - 2021 January

| School Name | Location | Sample ID | Lead (Pb) mg/L | Lead Result | Copper (Cu) mg/L | Copper Result | Next Steps: To be updated as work progresses. All schools have clean drinkable bottled water available. |
|--|---|----------------------|----------------|---------------|------------------|---------------|---|
| Antigonish Education Centre | Fountain 1-Main Entrance | ACO11310 | <0.0005 | Passed | 0.0150 | Passed | |
| Antigonish Education Centre | Fountain 2-Grade 1-2 Wing | ACO11311 | <0.0005 | Passed | 0.0360 | Passed | |
| Antigonish Education Centre | Fountain 3-Pre-Primary | ACO11312 | <0.0005 | Passed | 0.0210 | Passed | |
| Antigonish Education Centre | Fountain 4-by stairwell-2nd floor | ACO11313 | 0.0007 | Passed | 0.0430 | Passed | |
| Antigonish Education Centre | Fountain 5-Wing 3 on 2nd floor | ACO11314 | <0.0005 | Passed | 0.0180 | Passed | |
| Antigonish Education Centre | Fountain 6-Wing 4 - on 2d floor | ACO11315 | <0.0005 | Passed | 0.0570 | Passed | |
| Antigonish Education Centre | Food Prep 1-2nd floor-YSF-Rm 2108 | ACO11316 | <0.0005 | Passed | 0.0190 | Passed | |
| Antigonish Education Centre | Food Prep 2-Rm 1005-next to door | ACO11317 | <0.0005 | Passed | 0.0180 | Passed | |
| Antigonish Education Centre | Food Prep 3-Rm 1005-back corner | ACO11318 | 0.0006 | Passed | 0.0120 | Passed | |
| Antigonish Education Centre | Food Prep 4-Rm 1113-Staff Room | ACO11319 | <0.0005 | Passed | 0.0180 | Passed | |
| Antigonish Education Centre | Food Prep 5-Rm 1311-Pre-primary | ACO11320 | <0.0005 | Passed | 0.0200 | Passed | |
| Antigonish Education Centre | Food Prep 6-Rm 1317-Pre-primary | ACO11321 | <0.0005 | Passed | 0.0170 | Passed | |
| Antigonish Education Centre | Food Prep 7-Rm 1318-Pre-primary | ACO11322 | <0.0005 | Passed | 0.0200 | Passed | |
| Antigonish Education Centre | Food Prep 8-Rm 1319-Pre-primary | ACO11323 | <0.0005 | Passed | 0.0410 | Passed | |
| Bayview Education Centre | Fountain 1 - Nearest to Building Entrance | ACO11448 | <0.0005 | Passed | 0.2500 | Passed | |
| Bayview Education Centre | Fountain 2 - 1st Floor | ACO11449 | <0.0005 | Passed | 0.1100 | Passed | |
| Bayview Education Centre | Fountain 3 - 2nd Floor | ACO11450 | <0.0005 | Passed | 0.1700 | Passed | |
| Bayview Education Centre | Fountain 4 - 2nd Floor | ACO11451 | <0.0005 | Passed | 0.1600 | Passed | |
| Bayview Education Centre | Food Prep 1 - Cafeteria/Kitchen Room 1302 (double sink) | ACO11452 | 0.0046 | Passed | 0.2400 | Passed | |
| Bayview Education Centre | Food Prep 2 - Cafeteria/Kitchen Room 1302 (dish rinsing) | BEC-001-PW20-KS1-L1 | 0.0009 | Passed | 0.0460 | Passed | Exceedance remediated |
| Bayview Education Centre | Food Prep 3 - Cafeteria/Kitchen Room 1302 (hand) | ACO11454 | 0.0032 | Passed | 0.1500 | Passed | |
| Bayview Education Centre | Food Prep 4 - Staff Lounge | ACO11455 | <0.0005 | Passed | 0.1200 | Passed | |
| Bayview Education Centre | Food Prep 5 - Daycare Pre Primary | ACO11456 | 0.0012 | Passed | 0.2000 | Passed | |
| Bayview Education Centre | Food Prep 6 - YSF | ACO11457 | 0.0016 | Passed | 0.1100 | Passed | |
| Bayview Education Centre | Food Prep 7 - FST Room 2108 - back counter sink-right | BEC-001-PW20-KS1-L1 | 0.0040 | Passed | 0.5900 | Passed | |
| Bayview Education Centre | Food Prep 8 - FST Room 2108 - back counter sink-left side | BEC-002-PW20-KS1-L1 | 0.0040 | Passed | 0.5600 | Passed | |
| Bayview Education Centre | Food Prep 9 - FST Room 2108 - work station near window | BEC-003-PW20-KS1-L1 | 0.0080 | Exceeds Limit | 0.6400 | Passed | Re-sampled 01/18/21, Non-potable signage posted |
| Bayview Education Centre | Food Prep 10 - FST Room 2108 - work station near door | BEC-004-PW20-KS1-L1 | 0.0090 | Exceeds Limit | 0.2700 | Passed | Re-sampled 01/18/21, Non-potable signage posted |
| Bayview Education Centre | Fountain 5 - Gym Fountain | ACO11668 | <0.0005 | Passed | 0.2900 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Fountain 1 - Next to Pre-Primary room 1203 | ACO11458 | <0.0005 | Passed | 0.0890 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Fountain 2 - Down the Hall From Teachers Lounge | ACO11459 | <0.0005 | Passed | 0.0190 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Fountain 3 - Gym Hallway 1501 | ACO11460 | 0.0021 | Passed | 0.0280 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Fountain 4 - Before Family Studies | ACO11461 | <0.0005 | Passed | 0.0710 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Fountain 5 - End of Hall Road Side | CBHA-001-PW20-FN2 | 0.0011 | Passed | 0.1500 | Passed | Exceedance remediated |
| Cape Breton Highlands Education Centre/Academy | Food Prep 1 - Cafeteria Kitchen Handwashing Sink | ACO11463 | 0.0020 | Passed | 0.1700 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Food Prep 2 - Cafeteria Kitchen Dish Rinse Station | ACO11464 | 0.0025 | Passed | 0.1200 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Food Prep 3 - Cafeteria Kitchen next to toaster | CBHA-001-PW20-KS1-L1 | 0.0009 | Passed | 0.1100 | Passed | Exceedance remediated |
| Cape Breton Highlands Education Centre/Academy | Food Prep 4 - YSF room 1202 | ACO11466 | 0.0031 | Passed | 0.0600 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Food Prep 5 - Pre-Primary | ACO11467 | 0.0012 | Passed | 0.0820 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Food Prep 6 - Staff Lunchroom | ACO11468 | 0.0005 | Passed | 0.0430 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Food Prep 7 - Family Studies - 1st sink against the wall | ACO11469 | 0.0019 | Passed | 0.1500 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Food Prep 8 - Family Studies - 2nd sink against wall | ACO11470 | 0.0020 | Passed | 0.1100 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Food Prep 9 - Family Studies - Island Sink hallway side | ACO11471 | 0.0018 | Passed | 0.1100 | Passed | |
| Cape Breton Highlands Education Centre/Academy | Food Prep 10 - Cafeteria Kitchen island sink wall side | ACO11472 | 0.0023 | Passed | 0.2200 | Passed | |
| Chedabucto Education Centre/ Guysborough | Fountain 1 - across from YSF ROOM 20 | ACO11394 | <0.0005 | Passed | 1.8000 | Passed | |
| Chedabucto Education Centre/ Guysborough | Fountain 2 - outside of Gr. 2 & 3 classrooms | ACO11395 | 0.0005 | Passed | 0.8500 | Passed | |
| School Name | Location | Sample ID | Lead (Pb) mg/L | Lead Result | Copper (Cu) mg/L | Copper Result | Next Steps: To be updated as work progresses. All schools have clean drinkable bottled water available. |
| Chedabucto Education Centre/ Guysborough | Fountain 3 - next to room 126 | ACO11396 | <0.0005 | Passed | 1.9000 | Passed | |
| Chedabucto Education Centre/ Guysborough | Fountain 4 - across from MultiMedia Room | ACO11397 | <0.0005 | Passed | 1.5000 | Passed | |
| Chedabucto Education Centre/ Guysborough | Fountain 5 - across from Rec. Office | ACO11398 | <0.0005 | Passed | 0.3900 | Passed | Exceedance remediated |
| Chedabucto Education Centre/ Guysborough | Food Prep 1-YSF room 132-by window | ACO11399 | 0.0005 | Passed | 0.3300 | Passed | Exceedance remediated |
| Chedabucto Education Centre/ Guysborough | Food Prep 2-YSF room 132-3rd in the room | ACO11400 | <0.0005 | Passed | 2.0000 | Passed | |
| Chedabucto Education Centre/ Guysborough | Food Prep 3-YSF room 132-2nd in the room | ACO11401 | 0.0015 | Passed | 0.3600 | Passed | Exceedance remediated |
| Chedabucto Education Centre/ Guysborough | Food Prep 4-YSF room 132-1st in the room | ACO11402 | 0.0006 | Passed | 1.9000 | Passed | |
| Chedabucto Education Centre/ Guysborough | Food Prep 5-Cafeteria Kitchen | ACO11403 | 0.0009 | Passed | 0.0970 | Passed | Exceedance remediated |
| Chedabucto Education Centre/ Guysborough | Food Prep 6 - Room 25 Staff Room | ACO11613 | <0.0005 | Passed | 0.1200 | Passed | |
| Chedabucto Education Centre/ Guysborough | Food Prep 7 - YSF Room 113 Kitchen Tap | ACO11614 | <0.0005 | Passed | 0.3100 | Passed | Exceedance remediated |
| Dalbrae Academy | Fountain 1 - outside of staff room | ACO11473 | <0.0005 | Passed | 0.0940 | Passed | |
| Dalbrae Academy | Fountain 2 - Gymnasium | ACO11474 | <0.0005 | Passed | 0.0970 | Passed | |
| Dalbrae Academy | Fountain 3 - Blue Wing | ACO11475 | <0.0005 | Passed | 0.1200 | Passed | |
| Dalbrae Academy | Fountain 4 - Green Wing | ACO11476 | <0.0005 | Passed | 0.0750 | Passed | |
| Dalbrae Academy | Fountain 5 - Red Wing | ACO11477 | <0.0005 | Passed | 0.1300 | Passed | |
| Dalbrae Academy | Food Prep 1-Admin. Room Sink | ACO11478 | 0.0016 | Passed | 0.1500 | Passed | |

| | | | | | | | |
|--|---|-------------------|-----------------------|--------------------|-------------------------|----------------------|--|
| Dalbrae Academy | Food Prep 2-Staff Room | ACO11479 | <0.0005 | Passed | 0.0740 | Passed | |
| Dalbrae Academy | Food Prep 3 -Cafeteria Kitchen -sink sgainst sall | ACO11533 | <0.0005 | Passed | 0.0720 | Passed | |
| Dalbrae Academy | Food Prep 4-Cafeteria Kitchen - sink center island | ACO11657 | 0.0007 | Passed | 0.1100 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 1 - Staff Room - Refill Station | ACO11327 | <0.0005 | Passed | 0.0050 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 1 - Staff Room - Refill Station | ACO11327 | 0.0075 | Exceeds Limit | 0.3600 | Passed | Removed from service |
| Dr John Hugh Gillis Regional High School | Fountain 2 - Wing 4 by Music Room 2123 | ACO11328 | 0.0000 | Passed | 0.1100 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 2 - Wing 4 by Music Room 2123 | ACO11328 | 0.0041 | Passed | 0.3100 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 3 - Refill Station - next to room 2014 | ACO11329 | <0.0005 | Passed | 0.0980 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 3 - Refill Station - next to room 2014 | ACO11329 | 0.0010 | Passed | 0.1800 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 4 - Grade 12 area next to washrooms | ACO11330 | <0.0005 | Passed | 0.1800 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 4 - Grade 12 area next to washrooms | ACO11330 | 0.0010 | Passed | 0.2800 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 5 - Gym -next to boys change room | ACO11331 | 0.0006 | Passed | 0.1100 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 5 - Gym -next to boys change room | ACO11331 | 0.0007 | Passed | 0.2300 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 6 - Gym - next to girls change room | ACO11332 | <0.0005 | Passed | 0.0970 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 6 - Gym - next to girls change room | ACO11332 | 0.0011 | Passed | 0.1700 | Passed | |
| Dr John Hugh Gillis Regional High School | Fountain 7 - Grade 10 area next to washrooms | ACO11333 | <0.0005 | Passed | 0.0520 | Passed | |
| Dr John Hugh Gillis Regional High School | Food Prep 1 - Community Living | ACO11334 | <0.0005 | Passed | 0.0620 | Passed | |
| Dr John Hugh Gillis Regional High School | Food Prep 5 - Second Floor Cooking Lab - individual sink | ACO11338 | 0.0047 | Passed | 0.1300 | Passed | |
| Dr John Hugh Gillis Regional High School | Food Prep 6 - Second Floor Cooking Lab - first on left 2103 | ACO11339 | 0.0019 | Passed | 0.1200 | Passed | |
| Dr John Hugh Gillis Regional High School | Food Prep 7 - Second Floor Cooking Lab - second on left | ACO11340 | 0.0006 | Passed | 0.1000 | Passed | |
| Dr John Hugh Gillis Regional High School | Food Prep 8 - Second Floor Cooking Lab - second on right | ACO11341 | 0.0009 | Passed | 0.1500 | Passed | |
| Dr John Hugh Gillis Regional High School | Food Prep 9 - Second Floor Cooking Lab - first on right | ACO11342 | 0.0006 | Passed | 0.1400 | Passed | |
| Dr John Hugh Gillis Regional High School | Food Prep 10 - Cafeteria Kitchen small room | ACO11343 | <0.0005 | Passed | 0.2300 | Passed | |
| Dr John Hugh Gillis Regional High School | Food Prep 11 - Cafeteria Kitchen large room | ACO11344 | <0.0005 | Passed | 0.0760 | Passed | |
| Dr John Hugh Gillis Regional High School | Food Prep 4 - Second Floor Kitchen - Dishwashing Stn | ACO11539 | 0.0740 | Exceeds Limit | 0.2900 | Passed | Removed from service |
| Dr John Hugh Gillis Regional High School | Food Prep 3 - Second Floor Kitchen room 2104 | ACO11561 | 0.0004 | Passed | 0.3200 | Passed | |
| School Name | Location | Sample ID | Lead (Pb) mg/L | Lead Result | Copper (Cu) mg/L | Copper Result | Next Steps: To be updated as work progresses. All schools have clean drinkable bottled water available. |
| Dr John Hugh Gillis Regional High School | Food Prep 3 - Second Floor Kitchen room 2104 | DJHG-PW20-006-KS2 | 0.0014 | Passed | 0.2700 | Passed | Exceedance remediated |
| Dr John Hugh Gillis Regional High School | Food Prep 2 - Second Floor Old Office # 2040 | DJHG-PW20-005-KS2 | 0.0048 | Passed | 0.0090 | Passed | Exceedance remediated |
| Dr John Hugh Gillis Regional High School | Gym Female Washroom Tap 1 | ACO11570 | 0.0016 | Passed | 0.0430 | Passed | |
| Dr John Hugh Gillis Regional High School | Gym Male Washroom Tap 1 | ACO11571 | 0.0018 | Passed | 0.0680 | Passed | |
| Dr John Hugh Gillis Regional High School | Locker Room 1 - Washroom Tap 2 | ACO11572 | 0.0015 | Passed | 0.1400 | Passed | |
| Dr John Hugh Gillis Regional High School | Locker Room 1 - Washroom Tap 1 | ACO11573 | 0.0020 | Passed | 0.1100 | Passed | |
| Dr John Hugh Gillis Regional High School | Locker Room 2 - Washroom Tap | ACO11574 | 0.0025 | Passed | 0.2300 | Passed | |
| Dr John Hugh Gillis Regional High School | Locker Room 3 - Washroom Tap 1 | ACO11575 | <0.0005 | Passed | 0.0880 | Passed | |
| Dr John Hugh Gillis Regional High School | Locker Room 3 - Washroom Tap 2 | ACO11576 | 0.0009 | Passed | 0.1800 | Passed | |
| Dr John Hugh Gillis Regional High School | Locker Room 4 - Washroom Tap | ACO11577 | 0.0022 | Passed | 0.2000 | Passed | |
| Dr John Hugh Gillis Regional High School | Janitors Room Tap - Main Hallway | ACO11578 | 0.0000 | Passed | 0.0980 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Main Hallway - Tap 3 | ACO11581 | 0.0032 | Passed | 0.2200 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Grade 10 Hallway - Tap 1 | ACO11582 | 0.0010 | Passed | 0.0820 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Main Hallway - Tap 2 | ACO11583 | 0.0008 | Passed | 0.1000 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Grade 9 Hallway - Tap 2 | ACO11584 | 0.0024 | Passed | 0.2000 | Passed | |
| Dr John Hugh Gillis Regional High School | Auto Shop Tap - 1st floor | ACO11585 | <0.0005 | Passed | 0.1300 | Passed | |
| Dr John Hugh Gillis Regional High School | Wood Shop Tap | ACO11586 | 0.0230 | Exceeds Limit | 0.0610 | Passed | Non-potable source - signage posted |
| Dr John Hugh Gillis Regional High School | Boiler Room Tap - Auto Shop Hallway | ACO11587 | 0.0310 | Exceeds Limit | 1.7000 | Passed | Non-potable source - signage posted |
| Dr John Hugh Gillis Regional High School | Community Living Washroom - Auto Shop Hallway - Tap 1 | ACO11588 | 0.0017 | Passed | 0.1200 | Passed | |
| Dr John Hugh Gillis Regional High School | Community Living Washroom - Auto Shop Hallway - Tap 2 | ACO11589 | <0.0005 | Passed | 0.1100 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 10 Hallway - Tap 1 | ACO11590 | 0.0025 | Passed | 0.1900 | Passed | |
| Dr John Hugh Gillis Regional High School | Gender Neutral Washroom Tap | ACO11591 | <0.0005 | Passed | 0.1200 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 9 Hallway - Tap 3 | ACO11592 | 0.0007 | Passed | 0.2300 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Auto Shop Hallway - Tap 1 | ACO11593 | 0.0006 | Passed | 0.0390 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Auto Shop Hallway - Tap 2 | ACO11594 | 0.0011 | Passed | 0.0720 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 10 Hallway - Tap 2 | ACO11595 | 0.0047 | Passed | 0.2200 | Passed | |
| Dr John Hugh Gillis Regional High School | Janitors Room Tap - Auto Shop Hallway | ACO11596 | 0.0016 | Passed | 0.0920 | Passed | |
| Dr John Hugh Gillis Regional High School | Trades Room Tap | ACO11597 | 0.0017 | Passed | 0.0690 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 9 Hallway - Tap 1 | ACO11598 | 0.0010 | Passed | 0.1800 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 9 Hallway - Tap 2 | ACO11599 | 0.0010 | Passed | 0.2800 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Auto Shop Hallway - Tap 3 | ACO11600 | 0.0010 | Passed | 0.0740 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Grade 10 Hallway - Tap 2 | ACO11601 | 0.0010 | Passed | 0.0940 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Grade 9 Hallway - Tap 1 | ACO11602 | 0.0033 | Passed | 0.2500 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 10 Hallway - Tap 3 | ACO11618 | 0.0025 | Passed | 0.2600 | Passed | |
| Dr John Hugh Gillis Regional High School | Janitors Washroom Tap - Grade 9 Hallway | ACO11619 | 0.0023 | Passed | 0.0430 | Passed | |
| Dr John Hugh Gillis Regional High School | Trades Building Tap - Back Exterior of School | ACO11620 | 0.0011 | Passed | 0.1100 | Passed | |
| Dr John Hugh Gillis Regional High School | Cafeteria Kitchen - Room 2100 - Handwashing Sink | ACO11621 | 0.0007 | Passed | 0.1900 | Passed | |
| Dr John Hugh Gillis Regional High School | Main Office Handwashing Sink | ACO11622 | 0.0010 | Passed | 0.2300 | Passed | |
| Dr John Hugh Gillis Regional High School | Classroom 2102 Tap - Sewing Room | DJHG-PW20-001-KS1 | <0.0005 | Passed | 0.1200 | Passed | Exceedance remediated |
| Dr John Hugh Gillis Regional High School | Classroom 2100 Tap - Special Needs | ACO11624 | 0.0010 | Passed | 0.2200 | Passed | |
| Dr John Hugh Gillis Regional High School | Classroom 2198 Tap | ACO11625 | 0.0011 | Passed | 0.1400 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Main Hallway 2nd Floor - Tap 1 | ACO11626 | 0.0050 | Passed | 0.2200 | Passed | Exceedance remediated |

| School Name | Location | Sample ID | Lead (Pb) mg/L | Lead Result | Copper (Cu) mg/L | Copper Result | Next Steps: To be updated as work progresses. All schools have clean drinkable bottled water available. |
|--|---|-------------------|----------------|---------------|------------------|---------------|---|
| Dr John Hugh Gillis Regional High School | Girls Washroom - Main Hallway 2nd Floor - Tap 2 | ACO11627 | 0.0037 | Passed | 0.1700 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Main Hallway 2nd Floor - Tap 3 | ACO11628 | 0.0029 | Passed | 0.3100 | Passed | |
| Dr John Hugh Gillis Regional High School | Music Room 2123 Tap | ACO11629 | <0.0005 | Passed | 0.2000 | Passed | |
| Dr John Hugh Gillis Regional High School | Staff Washroom - Main Hallway 2nd Floor | ACO11630 | 0.0020 | Passed | 0.1300 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Main Hallway 2nd Floor - Tap 1 | ACO11631 | 0.0021 | Passed | 0.1300 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Main Hallway - Tap 1 | ACO11632 | 0.0021 | Passed | 0.1600 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Main Hallway 2nd Floor - Tap 3 | ACO11633 | 0.0011 | Passed | 0.2000 | Passed | |
| Dr John Hugh Gillis Regional High School | Classroom 2191 Tap | ACO11634 | 0.0023 | Passed | 0.2200 | Passed | |
| Dr John Hugh Gillis Regional High School | Art Room 2084 - Tap 1 | ACO11636 | 0.0005 | Passed | 0.1600 | Passed | |
| Dr John Hugh Gillis Regional High School | Art Room 2084 - Tap 2 | ACO11637 | 0.0008 | Passed | 0.1200 | Passed | |
| Dr John Hugh Gillis Regional High School | Art Room 2085 - Tap 1 | DJHG-PW20-005-US1 | 0.0015 | Passed | 3.8000 | Exceeds Limit | Lead exceedance remediated. Copper non-potable source - signage posted. |
| Dr John Hugh Gillis Regional High School | Art Room 2085 - Tap 2 | ACO11639 | 0.0014 | Passed | 0.1800 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Grade 9 Hallway - Tap 3 | ACO11641 | 0.0030 | Passed | 0.2000 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Grade 10 Hallway - Tap 3 | ACO11642 | 0.0022 | Passed | 0.1500 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 11 Hallway 2nd Floor - Tap 1 | DJHG-PW20-003-BS2 | 0.0006 | Passed | 0.2000 | Passed | Exceedance remediated |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 11 Hallway 2nd Floor - Tap 2 | ACO11644 | 0.0027 | Passed | 0.1700 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 11 Hallway 2nd Floor - Tap 3 | ACO11645 | 0.0016 | Passed | 0.2000 | Passed | |
| Dr John Hugh Gillis Regional High School | Janitors Room Tap - Grade 11 Hallway 2nd Floor | ACO11646 | 0.0005 | Passed | 0.1100 | Passed | |
| Dr John Hugh Gillis Regional High School | Guidance Office Tap - Grade 11 Hallway 2nd Floor | ACO11647 | <0.0005 | Passed | 0.2500 | Passed | |
| Dr John Hugh Gillis Regional High School | Doctor's Tap - Grade 12 Hallway 2nd Floor | ACO11648 | 0.0085 | Exceeds Limit | 0.5600 | Passed | Non-potable source - signage posted |
| Dr John Hugh Gillis Regional High School | Dr Office Washroom Tap | ACO11649 | 0.0007 | Passed | 0.0460 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Grade 11 Hallway 2nd Floor - Tap 1 | ACO11650 | 0.0015 | Passed | 0.1600 | Passed | |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Grade 12 Hallway 2nd Floor - Tap 2 | ACO11651 | 0.0040 | Passed | 0.3400 | Passed | Exceedance remediated |
| Dr John Hugh Gillis Regional High School | Boys Washroom - Grade 12 Hallway 2nd Floor - Tap 3 | ACO11652 | 0.0026 | Passed | 0.2200 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 12 Hallway 2nd Floor - Tap 1 | ACO11653 | 0.0035 | Passed | 0.3400 | Passed | |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 12 Hallway 2nd Floor - Tap 2 | ACO11654 | 0.0030 | Exceeds Limit | 0.3600 | Passed | Non-potable source - signage posted |
| Dr John Hugh Gillis Regional High School | Girls Washroom - Grade 12 Hallway 2nd Floor - Tap 3 | ACO11655 | 0.0041 | Passed | 0.3100 | Passed | |
| Dr John Hugh Gillis Regional High School | Janitor Room Grade 12 Hallway | ACO11656 | 0.0013 | Passed | 0.0570 | Passed | |
| Dr John Hugh Gillis Regional High School | School Plus Classroom - Female Washroom | ACO11658 | 0.0043 | Passed | 0.1800 | Passed | |
| Dr John Hugh Gillis Regional High School | School Plus Classroom - Male Washroom | ACO11659 | 0.0046 | Passed | 0.1500 | Passed | |
| Dr John Hugh Gillis Regional High School | Staff Washroom - 2nd floor by Music Room | ACO11660 | 0.0008 | Passed | 0.0960 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 1-2nd floor-YSF-room # 2108 | ACO11316 | <0.0005 | Passed | 0.0190 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 2-Rm 1005-closest to door | ACO11317 | <0.0005 | Passed | 0.0180 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 3-Rm 1005-back corner | ACO11318 | 0.0033 | Passed | 0.0120 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 4-Rm 1113-Staff Room | ACO11319 | 0.0021 | Passed | 0.0180 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 5-Room 1311-Pre-primary | ACO11320 | <0.0005 | Passed | 0.0200 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 6-Room 1317-Pre-primary | ACO11321 | <0.0005 | Passed | 0.0170 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 7-Room 1318-Pre-primary | ACO11322 | <0.0005 | Passed | 0.0200 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 8-Room 1319-Pre-primary | ACO11323 | 0.0007 | Passed | 0.0410 | Passed | |
| East Antigonish Education Centre/Academy | Fountain 1 - Early Years Hallway - next to Grade 4 | ACO11345 | <0.0005 | Passed | 0.1000 | Passed | |
| East Antigonish Education Centre/Academy | Fountain 2 - Elementary Wing | ACO11346 | <0.0005 | Passed | 0.1100 | Passed | |
| East Antigonish Education Centre/Academy | Fountain 3 - Bottle Refill Stn. Gym hallway | ACO11347 | <0.0005 | Passed | 0.1000 | Passed | |
| School Name | Location | Sample ID | Lead (Pb) mg/L | Lead Result | Copper (Cu) mg/L | Copper Result | Next Steps: To be updated as work progresses. All schools have clean drinkable bottled water available. |
| East Antigonish Education Centre/Academy | Fountain 4 - 2nd floor - Sr. Wing 10-12 | ACO11348 | <0.0005 | Passed | 0.1100 | Passed | |
| East Antigonish Education Centre/Academy | Fountain 5 - South Wing - Grade 5-6 | ACO11349 | <0.0005 | Passed | 0.1500 | Passed | |
| East Antigonish Education Centre/Academy | Fountain 6 - North Wing | ACO11350 | <0.0005 | Passed | 0.2000 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 9 - Family Studies - 2nd sink to the right | ACO11606 | <0.0005 | Passed | 0.1100 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 10 - Family Studies - 3rd sink to the right | ACO11607 | 0.0006 | Passed | 0.0770 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 11 - Family Studies - 4th sink to the right | ACO11608 | 0.0008 | Passed | 0.1600 | Passed | |
| East Antigonish Education Centre/Academy | Food Prep 12 - Family Studies - sink against the wall | ACO11609 | 0.0007 | Passed | 0.1700 | Passed | |
| East Richmond Education Centre | Fountain 1 - Wing 1 - by room 149 | ACO11425 | <0.0005 | Passed | 0.0570 | Passed | |
| East Richmond Education Centre | Food Prep 1 - Cafeteria Kitchen Sink by Storage Room | ACO11426 | 0.0006 | Passed | 0.0900 | Passed | |
| East Richmond Education Centre | Food Prep 2 - Cafeteria Kitchen - Prewash Station | ACO11427 | 0.0020 | Passed | 0.2200 | Passed | Exceedance remediated |
| East Richmond Education Centre | Food Prep 3 - Cafeteria Kitchen sink next to entry | ACO11428 | 0.0041 | Passed | 0.1900 | Passed | Exceedance remediated |
| East Richmond Education Centre | Food Prep 4 - Cafeteria Kitchen - handwashing | ACO11429 | 0.0028 | Passed | 0.1400 | Passed | |
| East Richmond Education Centre | Food Prep 5 - Family Studies - by window | ACO11430 | <0.0005 | Passed | 0.1200 | Passed | |
| East Richmond Education Centre | Food Prep 6 - Family Studies - by door entry | ACO11431 | <0.0005 | Passed | 0.1700 | Passed | |
| East Richmond Education Centre | Food Prep 7 - Family Studies - centre sinks | ACO11432 | 0.0007 | Passed | 0.1200 | Passed | |
| East Richmond Education Centre | Food Prep 8 - Day Care Tap 1 | ACO11662 | 0.0007 | Passed | 0.1300 | Passed | |
| East Richmond Education Centre | Food Prep 9 - Day Care Tap 2 | ACO11663 | <0.0005 | Passed | 0.0810 | Passed | |
| East Richmond Education Centre | Food Prep 11 - Pre Primary Tap | ERES-PW20-001-KS1 | 0.0018 | Passed | 0.7600 | Passed | Exceedance remediated |
| East Richmond Education Centre | Fountain 2 - Wing 1 - by room 165 | ACO11665 | <0.0005 | Passed | 0.2700 | Passed | |
| East Richmond Education Centre | Fountain 3 - Wing 2 - by room 178 | ACO11666 | <0.0005 | Passed | 0.2700 | Passed | Exceedance remediated |
| East Richmond Education Centre | Fountain 4 - Gym | ACO11667 | 0.0009 | Passed | 0.3100 | Passed | |
| East Richmond Education Centre | Food Prep 10 - Day Care Small Sink | ACO11671 | 0.0007 | Passed | 0.1300 | Passed | |
| Fanning Education Centre/ Canso Academy | Fountain 1 - Main Entrance - Bottle Refill Station | ACO11404 | <0.0005 | Passed | 0.7800 | Passed | |
| Fanning Education Centre/ Canso Academy | Fountain 2 - By room 123 | ACO11405 | <0.0005 | Passed | 0.3500 | Passed | |

| | | | | | | | |
|---|--|-------------------|-----------------------|--------------------|-------------------------|----------------------|--|
| Fanning Education Centre/ Canso Academy | Fountain 3 - By romm 137 | ACO11406 | <0.0005 | Passed | 0.5100 | Passed | |
| Fanning Education Centre/ Canso Academy | Fountain 4 - Wing 7-9 | ACO11407 | <0.0005 | Passed | 0.7800 | Passed | |
| Fanning Education Centre/ Canso Academy | Fountain 5 - Wing 10-12 | ACO11408 | <0.0005 | Passed | 0.3500 | Passed | |
| Fanning Education Centre/ Canso Academy | Food Prep 1 - Cafeteria Room 151 - double sink | ACO11409 | 0.0005 | Passed | 1.8000 | Passed | |
| Fanning Education Centre/ Canso Academy | Food Prep 2 - Cafeteria Kitchen room 117 - single sink | ACO11410 | 0.0028 | Passed | 1.4000 | Passed | |
| Fanning Education Centre/ Canso Academy | Food Prep 3 - Cafeteria Kitchen room 117 - double sink | ACO11411 | <0.0005 | Passed | 1.9000 | Passed | |
| Fanning Education Centre/ Canso Academy | Food Prep 4 - Multi-purpose room 114 - single sink | ACO11412 | 0.0015 | Passed | 0.4100 | Passed | |
| Fanning Education Centre/ Canso Academy | Food Prep 5 - Multi-purpose room 114 - island sink | ACO11413 | 0.0007 | Passed | 0.6000 | Passed | |
| Fanning Education Centre/ Canso Academy | Food Prep 6 - Staff Room 102 | ACO11610 | <0.0005 | Passed | 0.2800 | Passed | |
| Fanning Education Centre/ Canso Academy | Food Prep 7 - Cafeteria Room 113 Tap | ACO11611 | <0.0005 | Passed | 1.0000 | Passed | |
| Fanning Education Centre/ Canso Academy | Food Prep 8 - Janitors Staff Room 151 | ACO11612 | <0.0005 | Passed | 0.5100 | Passed | |
| Felix Marchand Education Centre | Food Prep 1 - Staff Lunchroom | ACO11433 | 0.0032 | Passed | 0.0260 | Passed | |
| H.M. MacDonald Elementary School | Fountain 1 - Next to Girls washroom | ACO11356 | <0.0005 | Passed | 0.0870 | Passed | |
| H.M. MacDonald Elementary School | Fountain 2 - Next to Janitors Storage room | ACO11357 | 0.0031 | Passed | 0.0830 | Passed | |
| H.M. MacDonald Elementary School | Food Prep 1-Lunch Room | ACO11358 | 0.0025 | Passed | 0.0660 | Passed | |
| Inverness Education Centre/Academy | Fountain 1 - Entrance | ACO11480 | <0.0005 | Passed | 0.0660 | Passed | |
| Inverness Education Centre/Academy | Fountain 2 - Back of School | ACO11481 | <0.0005 | Passed | 0.0300 | Passed | |
| Inverness Education Centre/Academy | Fountain 3 - Upstairs | ACO11482 | <0.0005 | Passed | 0.1600 | Passed | |
| School Name | Location | Sample ID | Lead (Pb) mg/L | Lead Result | Copper (Cu) mg/L | Copper Result | Next Steps: To be updated as work progresses. All schools have clean drinkable bottled water available. |
| Inverness Education Centre/Academy | Food Prep 1 - Staff Lounge | ACO11483 | 0.0001 | Passed | 0.0620 | Passed | |
| Inverness Education Centre/Academy | Food Prep 2 - FST Class | ACO11484 | 0.0004 | Passed | 0.0870 | Passed | |
| Pleasant Bay School | Food Prep 1 - Lunch Room | ACO11485 | 0.0019 | Passed | 0.0690 | Passed | |
| Pleasant Bay School | Sample Location 2 - Water Source | ACO11534 | 0.4000 | Exceeds Limit | 4.1000 | Exceeds Limit | Non-potable source - signage posted |
| Pleasant Bay School | Sample Location 3 - Boys Washroom Upstairs | ACO11535 | 0.0017 | Passed | 0.2400 | Passed | |
| Pleasant Bay School | Sample Location 4 - Girls Washroom Upstairs | ACO11536 | 0.0022 | Passed | 0.1700 | Passed | |
| Pleasant Bay School | Sample Location 5 - Washroom Downstairs | ACO11537 | 0.0006 | Passed | 0.1500 | Passed | Exceedance remediated |
| Richmond Education Centre/Academy | Fountain 1 - Main Floor Near Room 1800 | ACO11434 | <0.0005 | Passed | 0.2900 | Passed | |
| Richmond Education Centre/Academy | Fountain 2 - Near Room 1000 | ACO11435 | 0.0005 | Passed | 0.3000 | Passed | |
| Richmond Education Centre/Academy | Fountain 3 - Near Room 1101 | ACO11436 | <0.0005 | Passed | 0.4700 | Passed | |
| Richmond Education Centre/Academy | Fountain 4 - Second Floor Away From Cooking Lab | ACO11437 | <0.0005 | Passed | 0.4600 | Passed | |
| Richmond Education Centre/Academy | Fountain 5 - 2nd Floor Near Cooking Lab | ACO11438 | <0.0005 | Passed | 0.4600 | Passed | |
| Richmond Education Centre/Academy | Food Prep 1 - Cafeteria Kitchen-main sink | ACO11439 | 0.0013 | Passed | 0.2900 | Passed | |
| Richmond Education Centre/Academy | Food Prep 2 - Cafeteria Kitchen-food prep | ACO11440 | 0.0015 | Passed | 0.2000 | Passed | |
| Richmond Education Centre/Academy | Food Prep 3 - Cafeteria Kitchen-by entry door | ACO11441 | <0.0005 | Passed | 0.1700 | Passed | |
| Richmond Education Centre/Academy | Food Prep 4 - YSF Cooking Lab - room 1807 | ACO11442 | 0.0014 | Passed | 0.2600 | Passed | |
| Richmond Education Centre/Academy | Food Prep 5 - YSF Cooking Lab - room 1807 | ACO11443 | <0.0005 | Passed | 0.1600 | Passed | |
| Richmond Education Centre/Academy | Food Prep 6 - Teacher Staff Room 1608 | ACO11444 | <0.0005 | Passed | 0.2800 | Passed | |
| Richmond Education Centre/Academy | Food Prep 7 - 2nd Floor Cooking Lab Room 2013 - 1st Wall | ACO11445 | 0.0015 | Passed | 0.1200 | Passed | |
| Richmond Education Centre/Academy | Food Prep 8 - 2nd Floor Cooking Lab Room 2013 - 2nd | ACO11446 | 0.0012 | Passed | 0.2300 | Passed | |
| Richmond Education Centre/Academy | Food Prep 9 - 2nd Floor Cooking Lab Room 2013 - Island | ACO11447 | 0.0009 | Passed | 0.2900 | Passed | |
| St. Andrew Junior School | Fountain 1 - Corridor 011 by elevator | ACO11377 | <0.0005 | Passed | 0.0500 | Passed | |
| St. Andrew Junior School | Fountain 2 - Corridor 011 by Janitor's Closet | ACO11378 | <0.0005 | Passed | 0.0540 | Passed | |
| St. Andrew Junior School | Fountain 3 - Corridor 061 outside of Tech Ed | ACO11379 | <0.0005 | Passed | 0.2100 | Passed | |
| St. Andrew Junior School | Fountain 4 - Outside Science Room 228 | ACO11381 | 0.0013 | Passed | 0.0650 | Passed | |
| St. Andrew Junior School | Food Prep 1 - Nutrition Room # 207 separate sink | SAJS-002-PW20-KS1 | 0.0021 | Passed | 0.0870 | Passed | Exceedance remediated |
| St. Andrew Junior School | Food Prep 2 - Nutrition Room # 207 1st on the left | SAJS-003-PW20-KS1 | 0.0021 | Passed | 0.0490 | Passed | Exceedance remediated |
| St. Andrew Junior School | Food Prep 3 - Nutrition Room # 207 - 1st on the right | SAJS-004-PW20-KS1 | 0.0025 | Passed | 0.0510 | Passed | Exceedance remediated |
| St. Andrew Junior School | Food Prep 4 - Nutrition Room # 207 2nd on the right | SAJS-005-PW20-KS1 | 0.0025 | Passed | 0.0520 | Passed | Exceedance remediated |
| St. Andrew Junior School | Food Prep 5 - Nutrition Room # 207 2nd on the left | SAJS-006-PW20-KS1 | 0.0021 | Passed | 0.0350 | Passed | Exceedance remediated |
| St. Andrew Junior School | Food Prep 6 - YSF Room # 218 | ACO11388 | 0.0012 | Passed | 0.2900 | Passed | |
| St. Andrew Junior School | Food Prep 7 - Special Needs Room # 233 | SAJS-001-PW20-KS1 | <0.0005 | Passed | 0.0530 | Passed | Exceedance remediated |
| St. Andrew Junior School | Food Prep 8 - YSF Room # 101 | ACO11390 | 0.0025 | Passed | 0.1700 | Passed | |
| St. Andrew Junior School | Food Prep 9 - Class Room # 116 | ACO11391 | 0.0007 | Passed | 0.0850 | Passed | |
| St. Andrew Junior School | Food Prep 10 - Cafeteria Kitchen | | 0.0007 | Passed | 0.0360 | Passed | |
| St. Andrew's Consolidated School | Fountain 1 - Front Entrance outside room 3 | ACO11360 | <0.0005 | Passed | 0.0220 | Passed | |
| St. Andrew's Consolidated School | Fountain 2 - Outside room 152 | ACO11361 | 0.0035 | Passed | 0.2900 | Passed | |
| St. Andrew's Consolidated School | Fountain 3 - Outside room 153 | ACO11362 | 0.0032 | Passed | 0.3000 | Passed | |
| St. Andrew's Consolidated School | Fountain 4 - Hallway 111 | ACO11363 | <0.0005 | Passed | 0.1100 | Passed | |
| St. Andrew's Consolidated School | Fountain 5 - Room 113 Grade Primary porcelain fountain | ACO11364 | 0.0040 | Passed | 0.4300 | Passed | Exceedance remediated |
| St. Andrew's Consolidated School | Fountain 6 - Room 101 Grade primary porcelain fountain | ACO11365 | 0.0021 | Passed | 0.3100 | Passed | |
| St. Andrew's Consolidated School | Food Prep 1 - Room 128 - Cafeteria Kitchen - centre sink | ACO11366 | 0.0009 | Passed | 0.0480 | Passed | |
| School Name | Location | Sample ID | Lead (Pb) mg/L | Lead Result | Copper (Cu) mg/L | Copper Result | Next Steps: To be updated as work progresses. All schools have clean drinkable bottled water available. |
| St. Andrew's Consolidated School | Food Prep 2 - Room 128 - Cafeteria Kitchen - handwashing | ACO11367 | 0.0016 | Passed | 0.0420 | Passed | |
| St. Andrew's Consolidated School | Food Prep 3 - Room 128 - Cafeteria Kitchen - prep sink | ACO11368 | 0.0029 | Passed | 0.0250 | Passed | |
| St. Andrew's Consolidated School | Food Prep 4 - Room 128 - Cafeteria Kitchen - Dishwashing | ACO11369 | 0.0005 | Passed | 0.2500 | Passed | |
| St. Andrew's Consolidated School | Food Prep 5 - Room 101 - Primary | ACO11370 | 0.0005 | Passed | 0.0720 | Passed | |
| St. Andrew's Consolidated School | Food Prep 6 - Room 113 - Grade Primary | ACO11371 | 0.0010 | Passed | 0.1500 | Passed | |
| St. Andrew's Consolidated School | Food Prep 7 - Room 116 - Grade 1 kitchen sink | ACO11372 | 0.0010 | Passed | 0.1400 | Passed | Exceedance remediated |
| St. Andrew's Consolidated School | Food Prep 8 - Room 117 - Grade 1 kitchen sink | ACO11373 | 0.0002 | Passed | 0.1300 | Passed | Exceedance remediated |
| St. Andrew's Consolidated School | Food Prep 9 - Room 126A - Pre-Primary | ACO11374 | 0.0020 | Passed | 0.0880 | Passed | |

| | | | | | | | |
|---|--|--------------------|-----------------------|--------------------|-------------------------|----------------------|--|
| St. Andrew's Consolidated School | Food Prep 10 - Room 127 - Student Services | ACO11375 | 0.0026 | Passed | 0.1400 | Passed | |
| St. Andrew's Consolidated School | Food Prep 11 Room 138 - Staff Room | ACO11376 | 0.0002 | Passed | 0.1200 | Passed | |
| St. Mary's Education Centre/Academy | Fountain 1 - Outside of room 168 | ACO11415 | <0.0005 | Passed | 0.0018 | Passed | |
| St. Mary's Education Centre/Academy | Fountain 2 - Main Entrance | ACO11416 | <0.0005 | Passed | 0.1500 | Passed | |
| St. Mary's Education Centre/Academy | Fountain 3 - Main Hall - 2nd floor | ACO11417 | <0.0005 | Passed | 0.1300 | Passed | |
| St. Mary's Education Centre/Academy | Food Prep 1 - Family Studies - 1st sink - individual | ACO11418 | 0.0012 | Passed | 0.3800 | Passed | |
| St. Mary's Education Centre/Academy | Food Prep 2 - Island sink - 1st to the left | ACO11419 | 0.0007 | Passed | 0.0033 | Passed | |
| St. Mary's Education Centre/Academy | Food Prep 3 - island sink - 1st to the right | ACO11420 | <0.0005 | Passed | 0.0033 | Passed | |
| St. Mary's Education Centre/Academy | Food Prep 4 - island sink - 2nd to the right | ACO11421 | <0.0005 | Passed | 0.0030 | Passed | |
| St. Mary's Education Centre/Academy | Food Prep 5 - island sink - 2nd to the left | ACO11422 | <0.0005 | Passed | 0.0034 | Passed | |
| St. Mary's Education Centre/Academy | Food Prep 6 - Staff Room 109 | ACO11423 | <0.0005 | Passed | 0.0045 | Passed | |
| St. Mary's Education Centre/Academy | Food Prep 7 - Cafeteria Kitchen room 113 | ACO11424 | 0.0030 | Passed | 0.1100 | Passed | Exceedance remediated |
| St. Mary's Education Centre/Academy | Food Prep 8 - Room 111 Cafeteria Eating Area - sink | ACO11615 | 0.0065 | Passed | 0.1600 | Passed | Removed from service |
| St. Mary's Education Centre/Academy | Food Prep 10 - Room 118 YSF Kitchen Sink | ACO11616 | 0.0028 | Passed | 0.5100 | Passed | Exceedance remediated |
| St. Mary's Education Centre/Academy | Food Prep 9 - Room 113 Cafeteria Kitchen Sink | ACO11617 | 0.0007 | Passed | 0.0160 | Passed | |
| Strait Area Education and Recreation Centre | Fountain 1 - In the Gym | ACO11525 | <0.0005 | Passed | 0.1000 | Passed | |
| Strait Area Education and Recreation Centre | Fountain 2 - By the Library | ACO11487 | <0.0005 | Passed | 0.0510 | Passed | |
| Strait Area Education and Recreation Centre | Fountain 3 - Next to 3rd Floor Washrooms | ACO11488 | <0.0005 | Passed | 0.0470 | Passed | |
| Strait Area Education and Recreation Centre | Fountain 4 - 2nd floor hallway | ACO11669 | <0.0005 | Passed | 0.0590 | Passed | |
| Strait Area Education and Recreation Centre | Food Prep 1 - Food Lab 1st Sink on door side of 1st Island | ACO11526 | 0.0018 | Passed | 0.0380 | Passed | |
| Strait Area Education and Recreation Centre | Food Prep 2 - Food Lab room 252 - against the wall | ACO11527 | 0.0013 | Passed | 0.0370 | Passed | |
| Strait Area Education and Recreation Centre | Food Prep 3 - Cafeteria Kitchen Triple Sink | ACO11528 | <0.0005 | Passed | 0.0690 | Passed | |
| Strait Area Education and Recreation Centre | Food Prep 4 - Daycare Sink Right of Dishwasher | ACO11529 | <0.0005 | Passed | 0.1400 | Passed | |
| Strait Area Education and Recreation Centre | Food Prep 5 - YSF Double Sink (Rm 246) | ACO11530 | 0.0042 | Passed | 0.0890 | Passed | |
| Strait Area Education and Recreation Centre | Food Prep 6 - Teachers Staff Lunch Room 208 | ACO11494 | 0.0015 | Passed | 0.0950 | Passed | |
| Strait Area Education and Recreation Centre | Food Prep 7 - Cafeteria Kitchen Dish Rinse Station | SAREC-001-PW20-KS1 | 0.0047 | Passed | 0.2500 | Passed | Exceedance remediated |
| Strait Area Education and Recreation Centre | Food Prep 8 - Teen Health Room 305 | ACO11496 | 0.0012 | Passed | 0.5600 | Passed | |
| Strait Area Education and Recreation Centre | Food Prep 9 - Staff room 2nd Floor | ACO11670 | <0.0005 | Passed | 0.2900 | Passed | |
| Tamarac Education Centre | Fountain 1 - Before YSF Room | ACO11497 | <0.0005 | Passed | 0.0400 | Passed | |
| Tamarac Education Centre | Fountain 2 - Next to Gym | ACO11498 | <0.0005 | Passed | 0.0290 | Passed | |
| Tamarac Education Centre | Fountain 3 - Outside Classroom 2017 | ACO11499 | <0.0005 | Passed | 0.0500 | Passed | |
| Tamarac Education Centre | Fountain 4 - Upstairs | ACO11500 | <0.0005 | Passed | 0.0220 | Passed | |
| Tamarac Education Centre | Fountain 5 - Outside Upstairs Washroom | ACO11501 | <0.0005 | Passed | 0.0250 | Passed | |
| Tamarac Education Centre | Food Prep 1 - Cafeteria Sink at Doorway | ACO11502 | 0.0010 | Passed | 0.0280 | Passed | |
| School Name | Location | Sample ID | Lead (Pb) mg/L | Lead Result | Copper (Cu) mg/L | Copper Result | Next Steps: To be updated as work progresses. All schools have clean drinkable bottled water available. |
| Tamarac Education Centre | Food Prep 2 - Dish Rinse Station | ACO11503 | <0.0005 | Passed | 0.0390 | Passed | |
| Tamarac Education Centre | Food Prep 3 - Sink at Center Prep Station | ACO11504 | <0.0005 | Passed | 0.0200 | Passed | |
| Tamarac Education Centre | Food Prep 4 - Left Wall in YSF | ACO11505 | <0.0005 | Passed | 0.0240 | Passed | |
| Tamarac Education Centre | Food Prep 5 - Teachers Lounge | ACO11506 | <0.0005 | Passed | 0.0400 | Passed | |
| Tamarac Education Centre | Food Prep 6 - First on Right Wall by Classroom Entrance | ACO11507 | <0.0005 | Passed | 0.0260 | Passed | |
| Whycocomagh Education Centre | Fountain 1 - Washroom Across From Cafeteria | ACO11508 | <0.0005 | Passed | 0.4400 | Passed | |
| Whycocomagh Education Centre | Fountain 2 - Outside Family Studies | ACO11509 | <0.0005 | Passed | 0.3900 | Passed | |
| Whycocomagh Education Centre | Fountain 3 - Server Room 156 | ACO11510 | <0.0005 | Passed | 0.2900 | Passed | |
| Whycocomagh Education Centre | Food Prep 1 Cafeteria Kitchen Sink | ACO11511 | 0.0008 | Passed | 0.4500 | Passed | |
| Whycocomagh Education Centre | Food Prep 2 - Double Sink Next to Dishwasher | ACO11512 | 0.0012 | Passed | 0.3900 | Passed | |
| Whycocomagh Education Centre | Food Prep 3 - Day Care Small Sink | ACO11513 | <0.0005 | Passed | 0.3700 | Passed | |
| Whycocomagh Education Centre | Food Prep 4 - Day Care Double Sink | ACO11514 | <0.0005 | Passed | 0.2800 | Passed | |
| Whycocomagh Education Centre | Food Prep 5 - Family Studies Hall Side Double Sink | ACO11515 | 0.0007 | Passed | 0.3200 | Passed | |
| Whycocomagh Education Centre | Food Prep 6 - 1st Sink Island Door Side | ACO11516 | 0.0011 | Passed | 0.3600 | Passed | Exceedance remediated |
| Whycocomagh Education Centre | Food Prep 7 - Island Sink Window Side | ACO11517 | 0.0044 | Passed | 0.3500 | Passed | |
| Whycocomagh Education Centre | Food Prep 8 - Pre Primary | ACO11518 | 0.0008 | Passed | 0.3700 | Passed | |
| Whycocomagh Education Centre | Food Prep 9 - Wall Sink Window Side | ACO11519 | 0.0014 | Passed | 0.3100 | Passed | |
| Whycocomagh Education Centre | Food Prep 10 - Staff Room | ACO11520 | 0.0007 | Passed | 0.3900 | Passed | |